

PIMPRI CHINCHWAD MUNICIPAL CORPORATION

(W/S) DIVISION



Report Of Chemical Examination Of Water

NO-WS / LAB / 2120/2023

DATE - 26 / 08 / 2023

DATE OF RECEIPT - 25 / 08 / 2023

DATE OF EXAMINATION - 25 / 08 / 2023

NAME - विठ्ठलरावराव अजिंश मिडियाल रुग्ण
ADDRESS - योगावोधरणी, पिंपरी

SOURCE Pmc water

NO	TESTS	I.S Standards for Drinking Water	Result mg/lit	Result mg/lit	Conclusion
1	Turbidity	1 N.T.U Max	2.24 NTU		
2	pH	6.5 to 8.5	7.24		
3	Total Hardness (as CaCO ₃)	200 mg/lit	108 mg/lit		
4	Chloride	250 mg/lit	24 mg/lit		
5	Calcium	75 mg/lit	80.46 mg/lit		

NOTE - SAMPLE NOT DRAWN BY THIS LABORATORY

CHIEF CHEMIST

Water treatment plant
sector 23 Nigdi